

SKG-IKOB PRODUCTCERTIFICATE

637.653.02

Date of issue: 04-02-2019



Certificate holder

GIESSE S.p.A.
Via Tubertini 1
I-40054 Budrio (BO)
T: +39 51 8850677
E: infotechgiesse@schlegel.com
I: www.giesse.it



Declaration of SKG-IKOB

This certificate has been issued on the basis of BRL 3104 in accordance with the SKG-IKOB Regulations for Attestation, Certification and Inspection.

SKG-IKOB declares that the by or on behalf of the certificate owner produced building hardware product:

rim cam barrel hinge set of 3

delivered under logo / brand:

Giesse

delivered under type- and / or article number:

Domina HP 3 wings/3

meets class 3 STER according BRL 3104 and NEN 5089: 2009 if the product is indelibly marked with the SKG mark, as shown above.

For SKG-IKOB

A handwritten signature in blue ink, consisting of a stylized, cursive script.

ir. H.A.J. van Dartel
Certification manager

Verify at www.sterrenwijzer.nl if this certificate is still valid and actual.
This certificate contains 2 pages.

CERTIFICATE

SKG-IKOB Certificatie
Poppenbouwing 56
4191 NZ Geldermalsen

Postbus 202
4190 CE Geldermalsen

T 088-2440100
info@skgikob.nl
www.skgikob.nl

SKG-IKOB PRODUCTCERTIFICATE

GIESSE S.p.A.
Number: 637.653.02

page 2 of 2

1. PRODUCT

rim cam barrel hinge set of 3

PRODUCT TYPE

hinge

2. TECHNICAL SPECIFICATION

Operating:	N.A.
Construction:	1 barrel hinge of 3 parts: 2 frame-parts and 1 leaf-part
System:	rim
Material:	frame and leaf part: aluminium coated or anodised pen: hardened steel
Dimension:	frame-parts: 51x38x36 mm leaf-part: 73x38x36 mm
Fixing:	direct mounting: 6x M12x55 mm through at least 2 walls of $\geq 1,5$ mm contra plate: 6x M8x55 mm
Intended use:	metal, door-inward-opening, door-outward-opening inside and outside opening aluminium doors and windows

3. DELIVERY

The delivery includes an installation instruction:
I05370020QN/01-2019 - I0337002/04-2015

4. PERFORMANCES

A rim cam barrel hinge set of 3 according this certificate fulfils the relevant requirements of BRL 3104.

A window- or door set, in which this rim cam barrel hinge, set of 3 is installed according the installation instructions of the certificate holder meets at least burglar resistance class (RC) 3 of NEN 5096 and EN 1627, if:

- the façade element or the (profile-)system from which the element is manufactured is delivered under a (KOMO-)quality approval with respect to the aspect burglar resistance, in which the actual window or door type is admitted and the herein mentioned conditions are fulfilled.

A window or door, in existing buildings, in which this rim cam barrel hinge, set of 3 is installed according the installation instructions of the certificate holder, meets the requirements of the Police Mark Save Housing (PKVW) - Existing Building, if:

- the other aspects of the façade element also comply with the applicable PKVW Protection directive (publication CCV).
-