

# SKG-IKOB PRODUCTCERTIFICATE

## 637.863.01

Date of issue: 27-01-2022



### Certificate holder

GIESSE S.p.A.  
Via Tubertini 1  
I-40054 Budrio (BO)  
T: +39 51 8850677  
E: infotechgiesse@schlegel.com  
I: www.giesse.it



### Declaration of SKG-IKOB

This certificate has been issued on the basis of BRL 3104 in accordance with the SKG-IKOB Regulations for Attestation, Certification and Inspection.

SKG-IKOB declares that the by or on behalf of the certificate owner produced building hardware product:

#### window handle

delivered under logo / brand:

#### GIESSE

delivered under type- and / or article number:

**KORA (00960FVG)**  
**PRIMA 01191FVG02**  
**ASIA 01085FVG01**

meets class 3 STER according BRL 3104 and NEN 5089: 2009 if the product is indelibly marked with the SKG mark, as shown above.

For SKG-IKOB

A handwritten signature in blue ink, consisting of a stylized, cursive script that appears to be "H.A.J. van Dartel".

ir. H.A.J. van Dartel  
Certification manager

Verify at [www.sterrenwijzer.nl](http://www.sterrenwijzer.nl) if this certificate is still valid and actual.  
This certificate contains 2 pages.

SKG-IKOB Certificatie  
Poppenbouwing 56  
4191 NZ Geldermalsen

Postbus 202  
4190 CE Geldermalsen

T 088-2440100  
[info@skgikob.nl](mailto:info@skgikob.nl)  
[www.skgikob.nl](http://www.skgikob.nl)

CERTIFICATE

# SKG-IKOB PRODUCTCERTIFICATE

GIESSE S.p.A.  
Number: 637.863.01

page 2 of 2

**1. PRODUCT**  
window handle

**PRODUCT TYPE**  
window handle

---

## 2. TECHNICAL SPECIFICATION

Operating:	Mechanical operation
Construction:	1 handle with fork and drive rod security
System:	locking by cylinder
Material:	installation support: zamac with PVC insert handle: aluminium with various coatings fork: steel zinc coated drive rod security: steel zinc coated
Dimension:	installation support: 125 OR 135x34x19/21 mm fork: 22x22x5,0 mm drive rod security: 124x12/4x2,0 mm
Fixing:	2x M5
Intended use:	metal, window-inward-opening, window-outward-opening for windows in combination with mortice bolts

---

## 3. DELIVERY

The delivery includes an installation instruction:  
I09240010QN - 2022

---

## 4. PERFORMANCES

A window handle according this certificate fulfils the relevant requirements of BRL 3104.

A window- or door set, in which this window handle is installed according the installation instructions of the certificate holder meets at least burglar resistance class (RC) 3 of NEN 5096 and EN 1627, if:

the façade element or the (profile-)system from which the element is manufactured is delivered under a (KOMO-)quality approval with respect to the aspect burglar resistance, in which the actual window or door type is admitted and the herein mentioned conditions are fulfilled.

A window or door, in existing buildings, in which this window handle is installed according the installation instructions of the certificate holder, meets the requirements of the Police Mark Save Housing (PKVW) - Existing Building, if:

the other aspects of the façade element also comply with the applicable PKVW Protection directive (publication CCV).

---