

Classification report

Reaction to fire of construction products

Nr. 20-002706-PR04
(KB-K88-01-en-01)



Client Schlegel Ltd.
Henlow Industrial Estate
Henlow Camp
SG16 6DS Bedfordshire
United Kingdom

Basis
DIN EN 13501-1:2010-01
Fire classification of
construction products and
building elements
Part 1: Classification using test
data from reaction to fire tests

Notified Body **ift Rosenheim GmbH**
Theodor-Gietl-Straße 7-9
D-83026 Rosenheim

Notified Body No. **0757**
Issue **1**

Product / Building
material **sealant profiles**

Designation **"Product family FR;
"QL 48650";
"QL 48750"**

Instructions for use
This classification report on the
reaction to fire defines the
classification assigned to the
building material according to
its product name in conformity
with the methods set out in DIN
EN 13501-1.

This classification document
does not represent type
approval or certification of the
product.

Validity
The data and results given
relate solely to the tested and
described test specimen.

Notes on publication
The **ift** Guidance Sheet
"Conditions and Guidance for
the Use of **ift** test reports"
applies.
No part of this classification
report may be used or
reproduced as an extract.

Contents
The report contains a total of
6 pages

- 1 Introduction
- 2 Details of the classified
product
- 3 Test reports and test results
to justify this classification
- 4 Classification and field of
application
- 5 Restrictons



Klassifizierung zum Brandverhalten
DIN EN 13501-1

Class E

ift Rosenheim
17.12.2020

Dr. Ing. Odette Moarcas
Head of Testing Department
Fire Safety



Dr. rer.nat. Mihaela Buschbeck
Deputy Head of Testing Department
Fire Safety